AITKIN COUNTY CERTIFICATE OF INSTALLATION/NOTICE OF NONCOMPLIANCE

This certificate of installation/notice of noncompliance has been issued this 24 th day of, 20_14_ to certify compliance\noncompliance with Aitkin County's Subsurface Sewage Treatment System Ordinance. The premises covered by this certificate are legally described as:
Section 3 Township 46 Range 25 Lake Long Lake PERMIT NO. 40476 Owner Name Craig Stormen Address 30451 33644 Lone Attion MN 56431 Installer Name Tohn Benson Lz941 Type of System Inspected Mound Parcel Number 69-1-079200
 The certificate of installation/notice of noncompliance was based on No _1_ of the following: Inspection of the installation or construction as in accordance with the above referenced permit and application design. Review of as-built plans submitted in accordance with Subdivision 9.2 D of Aitkin County's Subsurface Sewage Treatment System Ordinance.
If the above permitted subsurface sewage treatment system is in noncompliance with Aitkin County's Subsurface Sewage Treatment System Ordinance, then the following shall serve as a Notice of Violation: 1) Statement of the findings of fact through inspections or investigations:
2) List of specific violations of Ordinance:
3) Requirements for correction or removal of violations:
4) Time schedule for compliance:
Failure to correct or remove the above violation(s) will result in this matter being turned over to the Aitkin County Attorney's Office for further legal action, which may result in revocation of licenses or registrations, fines and/or imprisonment.
INSPECTOR SIGNATURE Byan Hayran

INDIVIDUAL SEWAGE TREATMENT SYSTEM INSPECTION FORM **AITKIN COUNTY, MINNESOTA**

Township 46 25 Date of Inspection	n <u>7/24/2014</u> Permit Number <u>40476</u>	
Owner Craig Stormoen	Parcel Number 09-1-079200	
Project Address 30451 336 40 home	Installer John Benson	
City Aith Zip Code 56431		
New Repair	DIST. or DROP BOX & TYPE	
SETBACKS:	TRENCHES, BEDS, OR GRAVELLESS LEACHFIELD:	
Buildings to tank(s) 25'±	Trench depth	
Buildings to drainfield 60 ±	Trench depth	
Well(s) 50' or 100'	Trench bottom width	
Lake/Creek/Wetland 88'	Trench spacing	
	Drainfield rock below pipe	
SEPTIC TANKS: New_X Existing	Size of gravelless pipe	
Number of tanks installed	Depth of backfill	
Liquid capacity and type 1650 Tacobsen Combo	Absorption area: square feet	
Type of baffle Plastic	lineal feet	
Inspection pipes	MOUNDS:	
Manholes size 24"	Percent slope	
Manhole to grade Yes No	Upslope dike width 17'	
. 2	Downslope dike width 17'	
PUMPS: New_X Existing	Sideslope dike width	
Tank capacity and type	Drainfield rock below pipe 9"	
Pump manufacturer & model # Zohler BN98	Depth of sand below rock 3'	
Horsepower & GPM /2 HP	Perforation size & spacing 0.25 36"	
Feet of head	Pipe size & spacing 1.5' 4' 3 Latera	
Gallons per cycle	Dimensions of rock bed 10×25 Dimensions of sand base 26×41	
Size of discharge line	Final cover 18" top 6" bottom	
Type & location of alarm Electric-Tank	Final cover_10 10p 6 Bolleto	
Water meter		
DRAWING OF SYSTEM: (include soils)	P.L.	
Shallow 20 00 00 00 00 00 00 0		
Inspector's Comments:		
7	Man & Remain	
Inspector's Signature	Installer's Signature /// / 394/	
Rev:1/13 White County Yell	ow – Applicant Pink - Installer 4 477/	