

From: [Shannon Westerlund](mailto:Shannon.Westerlund@aitkin.mn.us)
To: ["rickyconnolly494@yahoo.com"](mailto:rickyconnolly494@yahoo.com)
Subject: Land Use Application# 2019-004220
Date: Thursday, March 21, 2019 10:41:00 AM
Attachments: [Erosion Control Checklist & Plan.pdf](#)

Application# 2019-004220

Hi Ricky,

Your application for a new residence with attached garage has been received and is under review. Please enter the following information/revisions to complete the application:

- Under Project Type enter the square footage of the main floor footprint including attached decks/porches/garages.
- Describe any decks/porches/ other attachments under project description.
- Excavation or fill of more than 200 cubic yards requires an additional Erosion Control Plan describing temporary and permanent management of runoff. Complete the Erosion Control Form attached and upload to application.
- Revise site drawing to show the proposed structure meets the 10 foot setback from both property lines, 3 foot setback from well, and 75 foot setback from lake to deck. Include the proposed attached garage and update dimensions of cabin as described under project description. **Note: If eaves are greater than 24 inches, setbacks are measured to eaves. If 24 inches or less, it is measured to the wall.
- You selected a Holding Tank to permit which is \$150 on the invoice, was this by accident? I see a holding tank was installed in August, 2018. If so, the item will be removed from the invoice.

Below is a direct link for you to access the application to make changes. First Log In and click 'Edit' at the top of the page. If you have any questions or need additional help feel free to call or email.

<https://pzpermit.co.aitkin.mn.us/view.php?id=197298#option-results>

Thank you!

Shannon Westerlund
Aitkin County Environmental Services/Zoning
209 2nd Street NW, Rm 100
Aitkin, MN 56431
218-927-7342
Fax: 218-927-4372
www.co.aitkin.mn.us