

SEWER DESIGN & INSTALLATION

JAROLD R. FARLEY
R.O. Box 472
McGregor, MN 55760

Bus. Lic. No. Reg. No.

Bus. Lic. No. L1919 Reg. No. 4744

218-839-4737

INVOICE		Date 50 Pt. 2217
R. 1	Park	•
Michard	1 EUN	
Irudy	Bunge	
	5	

Date	Description	Amount
	Comp. Inspetion	200,00
		•
	(Total	200.00
(47)		

A FINANCE CHARGE OF 1.5% PER MONTH, WILL BE APPLIED TO ANY BALANCE OVER 30 DAYS.

- Thank You For Your Business -



520 Lafayette Road North St. Paul, MN 55155-4194

## **Compliance Inspection Form**

**Existing Subsurface Sewage Treatment Systems (SSTS)** 

Doc Type: Compliance and Enforcement

<b>Inspection results</b> based on Minnesota Pollution Control Agency (MPCA) requirements and attached forms – additional local requirements may also apply.	For local tracking purposes:
Submit completed form to Local Unit of Government (LUG) and system owner within 15 days	
System Status	
System status on date (mm/dd/yyyy): 9/22/2017	
The state of the s	ppliant – Notice of Noncompliance de Requirements on page 3.)
Reason(s) for noncompliance (check all applicable)  Impact on Public Health (Compliance Component #1) – Imminent threat Other Compliance Conditions (Compliance Component #3) – Imminent Tank Integrity (Compliance Component #2) – Failing to protect grounds Other Compliance Conditions (Compliance Component #3) – Failing to Soil Separation (Compliance Component #4) – Failing to protect ground Operating permit/monitoring plan requirements (Compliance Component	threat to public health and safety vater protect groundwater lwater
Property Information Parcel ID# or Sec/Twp/Ra	ange: 20.0.058100
	n for inspection: trans. of property.
	's phone:
or	
	sentative phone: 218-426-5100
Local regulatory authority: Aitkin Co. planning & Zoning Regulatory authority: Aitkin Co. planning & Zoning Regulatory authority: 1860 combo gal. tank that pump up into a 15' x 25" pre	atory authority phone:218-927-7342
Comments or recommendations:	assure bed draintend
,	
Certification	
	an accompliance status of this system. No
I hereby certify that all the necessary information has been gathered to determine the determination of future system performance has been nor can be made due to unknown possible abuse of the system, inadequate maintenance, or future water usage.	
Inspector name:	cation number: C-4744
	cense number: L-1919
Inspector signature:	Phone number: 218-839-4737
Necessary or Locally Required Attachments	
Soil boring logs System/As-built drawing ☐ Forms p ☐ Other information (list):	per local ordinance

Pro	perty address: <u>19656 469th</u> . <sup>st</sup> .McGrego	or,Mn.55760	Inspector initials/Date: TRF. 9/22/2017 (mm/dd/yyyy)		
1.	Impact on Public Health — C	Compliance compone	And the state of t		
	Compliance criteria:		Verification method(s):		
	System discharges sewage to the ground surface.	☐ Yes ⊠ No	<ul><li>☑ Searched for surface outlet</li><li>☑ Searched for seeping in yard/backup in home</li></ul>		
	System discharges sewage to drain tile or surface waters.	☐ Yes ⊠ No	☐ Excessive ponding in soil system/D-boxes ☐ Homeowner testimony (See Comments/Explanation)		
	System causes sewage backup into dwelling or establishment.	☐ Yes ⊠ No	☐ "Black soil" above soil dispersal system		
	Any "yes" answer above indicates the system is an imminent threat to public health and safety.		<ul> <li>☐ System requires "emergency" pumping</li> <li>☐ Performed dye test</li> <li>☐ Unable to verify (See Comments/Explanation)</li> <li>☐ Other methods not listed (See Comments/Explanation)</li> </ul>		
	Comments/Explanation:		_ = with meaning not noted (eee comments Explanation)		
2.	Tank Integrity — Compliance	component #2 of 5			
	Compliance criteria:		Verification method(s):		
	System consists of a seepage pit, cesspool, drywell, or leaching pit.	☐ Yes ⊠ No	<ul><li>☑ Probed tank(s) bottom</li><li>☑ Examined construction records</li></ul>		
5	Seepage pits meeting 7080.2550 may be compliant if allowed in local ordinance.		Examined Tank Integrity Form (Attach)		
	Sewage tank(s) leak below their designed operating depth.	☐ Yes ⊠ No	<ul><li>☐ Observed liquid level below operating depth</li><li>☐ Examined empty (pumped) tanks(s)</li></ul>		
	If yes, which sewage tank(s) leaks:		Probed outside tank(s) for "black soil"		
	Any "yes" answer above indic system is failing to protect gr		<ul> <li>☐ Unable to verify (See Comments/Explanation)</li> <li>☐ Other methods not listed (See Comments/Explanation)</li> </ul>		
	Comments/Explanation:  Tank is at the proper level with very few solids.tank pumped by kangas ent.				
3.	Other Compliance Condition	Compliance compo	nont #2 of E		
			or appear to be structurally unsound.   Yes* No Unknown		
	b. Other issues (electrical hazards, etc.)	to immediately and advers	ely impact public health or safety. ☐ Yes* ☒ No ☐ Unknown		
	*System is an imminent threat to Explain:	public health and safety			

www.pca.state.mn.us • 651-296-6300 • 800-657-3864 • TTY 651-282-5332 or 800-657-3864 • Available in alternative formats wq-wwists4-31 • 3/16/12 Page 2 of 3

System is non-protective of ground water for other conditions as determined by inspector .  $\square$  Yes\*  $\square$  No

\*System is failing to protect groundwater.

Explain:

Property address: 196	356 469th.	st.McGregor,Mn	.55760
-----------------------	------------	----------------	--------

Inspector initials/Date: 9/22/2017 (mm/dd/yyyy)

4. Soft separation – Compilance component #4 of 5				
Date of installation: 5/26/2005 (mm/dd/yyyy)	Unknown	Verification method(s):		
Shoreland/Wellhead protection/Food beverage lodging?	⊠ Yes □ No	Soil observation does not expire. Pro observations by two independent pa unless site conditions have been alto	rties are sufficient,	
Compliance criteria:		requirements differ.		
For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead	☐ Yes ☐ No	Conducted soil observation(s) (Attach boring logs)		
Protection Area or not serving a food,		☐ Two previous verifications (Attach boring logs)		
beverage or lodging establishment:		☐ Not applicable (Holding tank(s), no drainfield)		
Drainfield has at least a two-foot vertical		☐ Unable to verify (See Comments/Explanation)		
separation distance from periodically saturated soil or bedrock.		Other (See Comments/Explanation)		
Non-performance systems built April 1,	⊠ Yes □ No	Comments/Explanation:		
1996, or later or for non-performance systems located in Shoreland or Wellhead		0-4" topsoil 10 yr 2/2		
Protection Areas or serving a food,		4-36" med. sand 10 yr 5/6		
beverage, or lodging establishment:		38-49" med. sand 7.5 yr 5/6		
Drainfield has a three-foot vertical separation distance from periodically		mottles @ 49"		
saturated soil or bedrock.*				
"Experimental", "Other", or "Performance"	☐ Yes ☐ No	Indicate depths or elevations		
systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules (7080.		Bottom of distribution media	99.	
2350 or 7080.2400 (Advanced Inspector		A. Bottom of distribution media	<del>99</del> .	
License required)		B. Periodically saturated soil/bedrock	96	
Drainfield meets the designed vertical separation distance from periodically		C. System separation	36"	
saturated soil or bedrock.		D. Boguired compliance constation*	26"	
Any "no" answer above indicates the system is  D. Required compliance separation* 36"  *May be reduced up to 15 percent if allowed by Local				
failing to protect groundwater.  Ordinance.				
5. Operating Permit and Nitrogen BMP* — Compliance component #5 of 5 Not applicable				
Is the system operated under an Operating	Permit?	☐ No If "yes", A below is requir	red	
Is the system required to employ a Nitroger	n BMP? ☐ Yes	☐ No If "yes", B below is requir	red	
BMP = Best Management Practice(s) specified in the system design				
If the answer to both questions is "no", this section does not need to be completed.				
Compliance criteria				
Operating Permit number:				
Have the Operating Permit requireme	nts been met?	☐ Yes ☐ No		
b. Is the required nitrogen BMP in place and properly functioning? ☐ Yes ☐ No				
Any "no" answer indicates Noncompliance.				
paG2	*			

**Upgrade Requirements** (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.



## Sewer Design & Installation JAROLD R. FARLEY

P.O. Box 472 McGregor, MN 55760 Bus. Lic. No. L1919 Reg. No. 4744

218-839-4737 cell

