



34753 390th Place • Aitkin, MN 56431

Phone: 218.97.4125 • Fax 218.927.4471

Toll Free: 800.450.4125

rittersewer@hotmail.com • www.rittersewer.com

SEPTIC SYSTEM REVIEW FOR

Ted Lindahl

Parcel # 07-1-111400

29721 407th Place

Property located in Nordland Township

August 8, 2019

The above mentioned property has an existing holding tank that they would like to replace with new holding tanks. We are proposing to install a 1,650 gallon precast concrete septic tank (2 compartment) and a 1,500 gallon precast concrete septic tank to be used as holding tanks.

2" high density Styrofoam will be placed on top and 4' down on sides and ends of both tanks. Alarm will be placed in last tank to monitor sewage depth at 75% capacity. Tanks will meet 10' from structures, 50' from all wells and 75' setback from o.h.w of spirit lake.

There is an existing outhouse with an open pit under it that will also be removed at the same time of new tank installation.

The homeowner has entered into a pumping contract with Goble Sewer Service (see attached).

Sincerely,

Mark P. Ritter
Ritter Sewer & Excavating, Inc.

1 of 6