

C. MAINTENANCE PLANS

PARAMETER	LOCATION	FREQUENCY
300 GPD 600 GPD	Read Event Counter	Once a month or when present
Calibrate pump out gallons	Measure pump tank and calculate gallons pumped out per event	Calibrate system when installed and in operation. Check calibration number at 1st year inspection and every one after
Report monthly readings to Aitkin Co. Or inspector (once a year)	Keep records of monthly readings	Once a year submit report to Aitkin Co.

D. MITIGATION PLAN:

Have system Inspected

I hereby certify with my signature as the designer, that all data for the operating permit application is true and correct to the best of my knowledge. I agree to indemnify and hold Aitkin County harmless from loses, damages, costs and charges that may be incurred by the County because of the information submitted with this application.

Jeff Brummer
Signature

L-1347
License Number

9/18/2018
Date

Jeff Brummer
Name (please print)

7540 Burr Ln. Brainerd MN 56401
Address

(218) 821-0704
Telephone #