

Terry B. Neff

From: Terry B. Neff
Sent: Thursday, June 18, 2020 11:42 AM
To: kurtjmears@gmail.com
Subject: FW: soil erosion letter
Attachments: 1598_001.pdf

Kurt,

I just became aware that there may be fill within 5 feet of the side lot line(s). As part of your erosion control plan all fill must be at least 5 feet from the lot lines. The erosion control plan must include a drawing showing where the erosion control measures, in the attached letter, are being implemented with direction arrows indicating direction of surface flow.

Let me know if you have any questions.

Terry

From: Terry B. Neff
Sent: Wednesday, June 17, 2020 3:03 PM
To: kurtjmears@gmail.com
Cc: Shannon Westerlund <shannon.westerlund@co.aitkin.mn.us>; Kimberly Burton <kimberly.burton@co.aitkin.mn.us>
Subject: soil erosion letter

Kurt,

See attached letter from Steve Hughes, SWCD Manager, to me regarding the erosion and runoff control measures for your proposed garage project. The 4 recommendations in this letter must be incorporated into your erosion control plan as part of the permit application.

Let me know if you have any questions.

Regards!

Terry Neff
Environmental Services Director

From: Aitkin Co Environmental <donotreply@co.aitkin.mn.us>
Sent: Wednesday, June 17, 2020 2:44 PM
To: Terry B. Neff <terry.neff@co.aitkin.mn.us>
Subject: Attached Image