

**From:** [Shannon Westerlund](#)  
**To:**  
**Cc:** [Kimberly Burton](#)  
**Subject:** Permit App# 2020-005613  
**Date:** Tuesday, April 28, 2020 4:31:00 PM

---

App# 2020-005613 Denied

Amy,

Your permit request for a 25'x6' porch has been received. The required structure setback from Big Sandy Lake is 75 feet. The proposed porch does not meet the required lake setback and would require a variance.

For this reason, your permit application is being denied and a refund will be issued back to your card. If you are interested in applying for a variance please follow this link for the application information.

<https://www.co.aitkin.mn.us/departments/enviro-svcs/variance-applicants.html>

If you have questions on the variance process, please contact Planning & Zoning at 218-927-7342.

Thank you,

**Shannon Westerlund**  
Aitkin County Planning & Zoning  
Environmental Services  
307 2nd Street NW, Rm 219, Aitkin, MN 56431  
218-927-7342  
Fax: 218-927-4372  
[www.co.aitkin.mn.us](http://www.co.aitkin.mn.us)