

45477 256th Ln. Aitkin MN 56431

## Soil Log #3B Alt Site B


		<input checked="" type="checkbox"/> Boring	<input type="checkbox"/> Pit	Elevation <u>91.4'</u>		Depth to SHWT <u>(+ 39")</u>		
Depth (in)	Texture	fragment %	matrix color	redox color	consistence	grade	shape	
0 - 6	Topsoil Sandy Loam	<35	10YR3/2		Loose	Loose	Granular	
6 - 20	Sandy Loam	<35	10YR5/4		Loose	Loose	Granular	
20 - 39	Med Sand	<35	10YR4/4	Hit a Rock	Loose	Loose	Granular	
		<35 35 - 50 >50			loose friable firm rigid	loose weak moderate strong	single grain granular blocky prismatic platy massive	
		<35 35 - 50 >50			loose friable firm rigid	loose weak moderate strong	single grain granular blocky prismatic platy massive	

45477 256th Ln. Aitkin MN 56431

## Soil Log #4B Alt Site B

		<input checked="" type="checkbox"/> Boring	<input type="checkbox"/> Pit	Elevation <u>92.5'</u>		Depth to SHWT <u>(+ 33")</u>		
Depth (in)	Texture	fragment %	matrix color	redox color	consistence	grade	shape	
0 - 6	Topsoil Sandy Loam	<35	10YR3/2		Loose	Loose	Granular	
6 - 27	Sandy Loam	<35	10YR5/4		Loose	Loose	Granular	
27 - 36	Med Sand	<35	10YR4/4	Hit a Rock	Loose	Loose	Granular	
		<35 35 - 50 >50			loose friable firm rigid	loose weak moderate strong	single grain granular blocky prismatic platy massive	
		<35 35 - 50 >50			loose friable firm rigid	loose weak moderate strong	single grain granular blocky prismatic platy massive	

I hereby certify this work was completed in accordance with MN 7080 and any local req's.


  
 Designer Signature

Brummer Septic LLC.

Company

L-1347

License #

Page 5 of 20