

**AITKIN COUNTY**  
**CERTIFICATE OF INSTALLATION/~~NOTICE OF NONCOMPLIANCE~~**

This certificate of installation/~~notice of noncompliance~~ has been issued this 24th day of September, 2019 to certify compliance/~~noncompliance~~ with Aitkin County's Subsurface Sewage Treatment System Ordinance.

The premises covered by this certificate are legally described as: \_\_\_\_\_  
4.80 AC. IN LOT 5 AS IN DOC 424041

Section 32 Township Aitkin Range 27 Lake Cedar Lake  
PERMIT NO. 44367 Owner Name Brian & Judy Sandberg  
Address 34293 442nd Pl, Aitkin, MN 56431  
Installer Name \_\_\_\_\_ Larry Liljenquist  
Type of System Inspected \_\_\_\_\_ Type 1 4BR Mound  
Parcel Number 01-0-079502

The certificate of installation/~~notice of noncompliance~~ was based on No 1 of the following:

- 1) Inspection of the installation or construction as in accordance with the above referenced permit and application design.
- 2) Review of as-built plans submitted in accordance with Subdivision 9.2 D of Aitkin County's Subsurface Sewage Treatment System Ordinance.

If the above permitted subsurface sewage treatment system is in noncompliance with Aitkin County's Subsurface Sewage Treatment System Ordinance, then the following shall serve as a Notice of Violation:

- 1) Statement of the findings of fact through inspections or investigations:  
\_\_\_\_\_  
\_\_\_\_\_

- 2) List of specific violations of Ordinance: \_\_\_\_\_  
\_\_\_\_\_

- 3) Requirements for correction or removal of violations: \_\_\_\_\_  
\_\_\_\_\_

- 4) Time schedule for compliance: \_\_\_\_\_

Failure to correct or remove the above violation(s) will result in this matter being turned over to the Aitkin County Attorney's Office for further legal action, which may result in revocation of licenses or registrations, fines and/or imprisonment.

INSPECTOR SIGNATURE Bryan Hargrave

Remnant

FIELD EVALUATION SHEET

Alternate  
sewer Site

PRELIMINARY EVALUATION DATE June 27, 2022 FIELD EVALUATION DATE June 27, 2022

PROPERTY OWNER: Brian & Judy Sandberg PHONE 218-429-1130

ADDRESS: 34293-442<sup>nd</sup> Place CITY, STATE, ZIP: Aitkin, Mn. 56431

LEGAL DESCRIPTION: \_\_\_\_\_

PIN# 01-0-079502 SEC 32 T 47 R 27 TWP NAME Aitkin

FIRE# \_\_\_\_\_ LAKE/RIVER Cedar LAKE CLASS \_\_\_\_\_ OHWL \_\_\_\_\_ FT.

DESCRIPTION OF SOIL TREATMENT AREAS

	AREA #1	AREA #2	REFERENCE BM ELEV. _____ FT.
DISTURBED AREAS	YES _____ NO <u>X</u>	YES _____ NO _____	REFERENCE BM DESCRIPTION _____
COMPACTED AREAS	YES _____ NO <u>X</u>	YES _____ NO _____	_____
FLOODING	YES _____ NO <u>X</u>	YES _____ NO _____	_____
RUN ON POTENTIAL	YES _____ NO <u>X</u>	YES _____ NO _____	_____
SLOPE %	<u>4</u>	_____	_____
DIRECTION OF SLOPE	<u>W-E</u>	_____	_____
LANDSCAPE POSITION	<u>N-S</u>	_____	_____
VEGETATION TYPES	<u>Weeded</u>	_____	_____

DEPTH TO STANDING WATER OR MOTTLED SOIL: BORING# 1 13", 1A 13", 2 \_\_\_\_\_, 2A \_\_\_\_\_

BOTTOM ELEVATION—FIRST TRENCH OR BOTTOM OF ROCK BED: #1 \_\_\_\_\_ FT., #2 \_\_\_\_\_ FT.

SOIL SIZING FACTOR: SITE #1 2.20, SITE #2 \_\_\_\_\_

CONSTRUCTION RELATED ISSUES: \_\_\_\_\_

LIC# L2132 SITE EVALUATOR SIGNATURE: Tom O'Neil

SITE EVALUATOR NAME: Tom O'Neil TELEPHONE# 218-927-6070

LUG REVIEW \_\_\_\_\_ DATE \_\_\_\_\_

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SOIL BORING LOGS ON REVERSE SIDE

REMNANT

SOILS DATA

DEPTH (INCHES)	TEXTURE	MUNSELL COLOR
0-6	loam	10Yr 2/2
6-13	Clay loam	10Yr 3/4
	Mottles at 13"	

SOILS DATA

DEPTH (INCHES)	TEXTURE	MUNSELL COLOR
Same Soil		

SOILS DATA

DEPTH (INCHES)	TEXTURE	MUNSELL COLOR
-------------------	---------	------------------

SOILS DATA

DEPTH (INCHES)	TEXTURE	MUNSELL COLOR
-------------------	---------	------------------

Remnant

Alternate Site

Existing mound

Driveway

house