

AITKIN COUNTY
CERTIFICATE OF INSTALLATION/~~NOTICE OF NONCOMPLIANCE~~

This certificate of installation/~~notice of noncompliance~~ has been issued this _____ day of _____, 20____ to certify compliance/~~noncompliance~~ with Aitkin County's Subsurface Sewage Treatment System Ordinance.

The premises covered by this certificate are legally described as: _____

Section _____ Township _____ Range _____ Lake _____
PERMIT NO. _____ Owner Name _____
Address _____
Installer Name _____
Type of System Inspected _____
Parcel Number _____

The certificate of installation/~~notice of noncompliance~~ was based on No ___ of the following:

- 1) Inspection of the installation or construction as in accordance with the above referenced permit and application design.

- 2) Review of as-built plans submitted in accordance with Subdivision 9.2 D of Aitkin County's Subsurface Sewage Treatment System Ordinance.

If the above permitted subsurface sewage treatment system is in noncompliance with Aitkin County's Subsurface Sewage Treatment System Ordinance, then the following shall serve as a Notice of Violation:

- 1) Statement of the findings of fact through inspections or investigations:

- 2) List of specific violations of Ordinance: _____

- 3) Requirements for correction or removal of violations: _____

- 4) Time schedule for compliance: _____

Failure to correct or remove the above violation(s) will result in this matter being turned over to the Aitkin County Attorney's Office for further legal action, which may result in revocation of licenses or registrations, fines and/or imprisonment.

INSPECTOR SIGNATURE _____

SUBSURFACE SEWAGE TREATMENT SYSTEM INSPECTION FORM
AITKIN COUNTY, MINNESOTA

2023-000987

Township Glen Date of Inspection 9/7/2023 App. Number 48185

Owner Glen Clear Lake Property LLC Parcel Number 09-0-059101

Project Address Across St. from 28441 315th Ave Installer Greg Westerlund

City Aitkin Zip Code 56431 TI ZBR PB

New Repair

DIST. or DROP BOX & TYPE Pressure Bed

SETBACKS:

Buildings to tank(s) 17'

Buildings to drainfield 24'

Well(s) 50' or 100' No well on property

Lake/Creek/Wetland —

TRENCHES, BEDS, OR GRAVELLESS LEACHFIELD:

Trench/Bed depth 12"

Trench/Bed length 26'

Trench/Bed bottom width 15'

Laterals
Trench spacing (5) 1.5" Lats; 0.25" / 30" sp.

Drainfield rock below pipe 6"

SEPTIC TANKS: New Existing

Number of tanks installed (1) Cement Combo 1500

Liquid capacity and type 1000 part combo

Type of baffle Plastic

Inspection pipes —

Manholes size 24"

Manhole to grade Yes No

Size of gravelless pipe —

Depth of backfill 12"

Absorption area: square feet 390 ft²

lineal feet —

MOUNDS:

Percent slope —

Upslope sand width —

Downslope sand width —

Sideslope sand width —

Drainfield rock below pipe —

Depth of sand below rock —

Perforation size & spacing —

Pipe size & spacing —

Dimensions of rock bed —

Dimensions of sand base —

Final cover —

PUMPS: New Existing

Tank capacity and type 500 part combo

Pump manufacturer & model # Zoeller BN152

Horsepower & GPM 0.4HP 37GPM

Feet of head 10'

Gallons per cycle 75GPC

Size of discharge line 2"

Type & location of alarm Elec. on tank

Water meter —

DRAWING OF SYSTEM: (include soils)

soil - Pit w/ installer
A 0-8" 10YR 3/2 LS < 35% cf
E 8-13" 7.5YR 4/3 LS < 35% cf
B 13-30" 7.5YR 4/4 CS < 35% cf
C 30"-52" 7.5YR 5/4 MS < 35% cf

Inspector's Comments: _____

Inspector's Signature Bryan Hargrave Installer's Signature _____











