

AITKIN COUNTY ENVIRONMENTAL SERVICES

**OPERATING PERMIT FOR WASTEWATER
TREATMENT AND DISPERSAL**

OPERATING PERMIT #: 350 **FEE:** 100.0
PERMITTEE: Ukura's Big Dollar Store **PHONE:** (218) 768-2666
ADDRESS: 41561 State Hwy 65
McGregor, MN 55760-
ZONING PERMIT # 37227 **PARCEL #:** 14-0-041802
ISSUE DATE: 9/15/2009 **RENEW DATE:** 5/31/2010
LEGALDESCRIPTION: 286 FT X 104 FT OF SE NE AS IN DOC# 241469

Aitkin County Environmental Services authorizes the Permittee to operate a wastewater treatment and dispersal system located on the above described property in accordance with the requirements of this permit.


This permit is effective on the issuance date identified above.


This permit and the authorization to treat and disperse from the above system shall expire on the above expiration date. The Permittee is not authorized to discharge after the date of expiration. The Permittee shall submit such information and forms as required by Aitkin County Environmental Services no later than thirty (30) days prior to the expiration date. When the required information is submitted and approved by Aitkin County Environmental Services, the permit may be renewed. This permit is not transferable from owner to owner.

I hereby certify with my signature as the permittee that I understand the provisions of this permit including the maintenance and monitoring requirements. I agree to indemnify and hold Aitkin County harmless from all loss, damages, costs and charges that may be incurred by use of this system and if I fail to comply with the provisions of this Operating Permit. If I sell this property during the life of the permit, I will inform the new owner(s) of the permit requirements and the need to renew the permit.

Signature of Permittee

Date





Signature of Permitting Authority

Date

If You have any questions regarding this permit, including the specific permit requirements, permit reporting or permit compliance status, please contact Aitkin County Environmental Services at 218-927-7342.

A. DESCRIPTION OF WASTEWATER TREATMENT AND DISPERSAL SYSTEM

Sewage will flow by gravity to three 1960 gallon septic tanks. The third septic tank will have a VBT 200 model aerator mounted in the inlet side of the tank to treat the wastewater to residential strength. The outlet side of the tank will have a PL 525 polylock commercial effluent filter to prevent solids from moving forward. The last tank will be a duplex timed dose lift station which will dose a 10' x 100' rockbed mound.

B. PERFORMANCE STANDARD REQUIREMENTS:

During the period beginning on the effective date (issuance date) of this permit and lasting until this permits expiration date, the Permittee is authorized to discharge from the wastewater treatment unit to subsurface dispersal. No surface discharge is permitted. The following parameters must be monitored and the results must be found within the compliance limits.

PARAMETER	COMPLIANCE LIMIT	SAMPLE LOCATION	SAMPLE FREQUENCY	SAMPLE TYPE	REPORTING FREQUENC
Flow, BOD, TSS	1200 GPD, 125 mg/l, 65 mg/l	Pump control, lift station	ANNUALLY	Grab	ANNUALLY

C. MAINTENANCE REQUIREMENTS:

PARAMETER	LOCATION	FREQUENCY
Pumps, Floats & Alarms, Daily flow, VBT	Septic tank(s)	EVERY 6 MONTHS

D. MONITORING AND REPORTING REQUIREMENTS:

Monitoring results obtained during each calendar year shall be submitted no later than December 31st of that year to:

Aitkin County Environmental Services
209 2nd Street NW
Aitkin, MN 56431

The monitoring reports shall be signed by the Permittee. Copies are to be retained by the Permittee.

The Permittee shall notify Aitkin County Environmental Services within thirty (30) days when monitoring results do not meet the monitoring plan requirements of this permit.

Monitoring plans may be modified as necessary and reapproved by Aitkin County Environmental Services.

Sampling and laboratory testing procedures shall be performed in accordance with Standard Methods and the testing and shall be performed by a Minnesota Department of Health approved laboratory. All sampling and testing costs shall be the responsibility of the Permittee.

Monitoring will be done by Septic Check

E. MITIGATION PLAN:

If surfacing occurs: verify cause and make any necessary repairs or reduce water use. If BOD and TSS are too high, add additional treatment. If flow exceeds limit: reduce flow, install water saving fixtures, pump the tank. A replacement septic system could be constructed.

F. SPECIAL REQUIREMENTS: