Subsurface Sewage Treatment System Management Plan

Property Owner:		Phone:		Date:	
		City:		Zip:	
performance of your se	n will identify the operation and ma eptic system. Some of these activi a licensed septic service provider	ities must be perf	•	•	
•	check every		My System need	ds to be checked	
	check every		every	months.	
Homeowner Management Tasks Leaks - Check (look, listen) for leaks intoilets and dripping faucets. Repair leaks promptly. Surfacing sewage - Regularly check for wet or spongy soil around your soil treatment area. Effluentfilter - Inspectand clean twice a year or more. Alarms - Alarm signals when there is a problem. Contact a service provider any time an alarm signals. Event counter or water meter - Record your water use. -recommend meter readings be conducted (choose one: Daily Monthly Yearly					
Professional M	lanagement Tasks				
€	Check to make sure tank is not	leaking			
€	Check and clean the in-tank effluent filter				
€	Check the sludge/scum layer levels in all septic tanks				
€	Recommend if tank should be pumped				
€	Check inlet and outlet baffles				
€	Check the drainfield effluent levels in the rock layer				
€	Check the pump and alarm system functions				
€	€ Check wiring for corrosion and function				
€ Check dissolved oxygen and effluent temperature in tank					
€	€ Provide homeowner with list of results and any action to be taken				
€	Flush and clean laterals if clean	outs exist			
"I understand it is my responsibility to properly operate and maintain the sewage treatment system on this property, utilizing the Management Plan. If requirements in the Management Plan are not met, I will promptly notify the permitting authority and take necessary corrective actions. If I have a new system, I agree to adequately protect the reserve area for future use as a soil treatment system."					
Property Owner Name:					
Designer Signature:					

See Reverse Side for Home Owner Management Log

Home Owner Maintenance Log

Activity	Date Accomplished				
Check frequently:					
Leaks: check for plumbing leaks					
Soil treatment area check for surfacing					
Lint filter: check, clean if needed					
Effluent screen: if owner-maintained					
Water usage rate (monitor frequency)					
Check annually:					
Caps: inspect, replace if needed					
Sludge & Scum/Pump					
Inlet & Outlet baffles					
Drainfield effluent leaks					
Pump, alarm, wiring					
Flush & clean laterals if cleanouts exists					
Other:					
Other:					
Notes:					
Mitigation/corrective action plan:					