

SAMPLING REPORT

Location: 21927 US 169

Aitkin

11-1-144400

Owner: Sherwood Forest

Use: RV Park

Service Company:

Septic Check

6074 Keystone Rd

Milaca, MN 56353

320-983-2447

Laboratory: AW Labs

Sample Date: 05/17/2024 Sample entered by: Heather Johnson Report submitted: 06/03/2024

Notes: Canterbury:

CBOD=3.36

TSS=4.2

FOG=<5

ONSITE SEWAGE SYSTEM SAMPLING DETAIL

COMPONENT	TYPE	SAMPLE	LIMIT	RESULT
Pump Tank Drainfeild dose tank	Effluent	FLOW	900 GPD	179
Pump Tank Drainfeild dose tank	Effluent	CBOD	220 mg/l	5.42
Pump Tank Drainfeild dose tank	Effluent	FOG	30 mg/l	<5
Pump Tank Drainfeild dose tank	Effluent	TSS	65 mg/l	8.2