

**AITKIN COUNTY ENVIRONMENTAL SERVICES  
OPERATING PERMIT FOR WASTEWATER  
TREATMENT AND DISPERSAL RENEWAL**

ISSUANCE DATE: 5 /31/2021  
RENEWAL PERIOD:ANNUALLY

OPERATING PERMIT # 576  
ZONING PERMIT #: 43640  
PARCEL #: 11-1-113300

PERMITTEE:Mike Briggs

TELEPHONE: (320) 983-2447

MAILING ADDRESS:  
44655 237TH LANE  
AITKIN, MN 56431

PROPERTY ADDRESS:  
44655 237TH LANE  
AITKIN, MN 56431

LEGAL DESCRIPTION: PT LOTS 20,21,22 IN DOC 438306 (TRACT A)

Aitkin County Environmental Services authorizes the Permittee to operate a wastewater treatment and dispersal system located on the above described property in accordance with the requirements of this permit.

This permit is effective on the issuance date identified above.


This permit and the authorization to treat and disperse from the above system is valid through the renewal period identified above. The Permittee is not authorized to discharge after the renewal period. The Permittee shall submit such information and forms as required by Aitkin County Environmental Services no later than thirty (30) days prior to the expiration date. When the required information is submitted and approved by Aitkin County Environmental Services, the permit may be renewed. This permit is not transferable from owner to owner.

**I hereby certify with my signature as the permittee that I understand the provisions of this permit including the maintenance and monitoring requirements. I agree to indemnify and hold Aitkin County harmless from all loss, damages, costs and charges that may be incurred by use of this system and if I fail to comply with the provisions of this Operating Permit. If I sell this property during the life of the permit, I will inform the new owner(s) of the permit requirements and the need to renew the permit.**

  
Signature of Permittee

  
Date

  
Signature of Permitting Authority

  
Date

If you have any questions regarding this permit, including the specific permit requirements, permit reporting or permit compliance status, please contact Aitkin County Environmental Services at 218-927-7342.

**A. DESCRIPTION OF WASTEWATER TREATMENT AND DISPERSAL SYSTEM**

1600 reverse flow septic / treatment tank, 1000 gallon flow eq tank, 10' x 38' - 1' clean sand lift mound

**B. PERFORMANCE STANDARD REQUIREMENTS:**

During the period beginning on the effective date (issuance date) of this permit and lasting until this permit's expiration date, the Permittee is authorized to discharge from the wastewater treatment unit to subsurface dispersal. No surface discharge is permitted. The following parameters must be monitored and the results must be found within the compliance limits.

| PARAMETER           | COMPLIANCE LIMIT | SAMPLE LOCATION | SAMPLE FREQUENCY | SAMPLE TYPE           | REPORTING FREQUENC |
|---------------------|------------------|-----------------|------------------|-----------------------|--------------------|
| Seperation Distance | 12"              |                 |                  |                       | ANNUALLY           |
| Fecal Coliform      | 1000             | pump tank       | Annually         | Measure in Field      | ANNUALLY           |
| TSS                 | 15mg/L           | pump tank       | Annually         | Measure in Field      | ANNUALLY           |
| 5-Day BOD           | 15mg/L           | pump tank       | Annually         | Measure in Field      | ANNUALLY           |
| Flow                | 450 GPD          | EC/ETM          | Monthly          | Record on a Log Sheet | ANNUALLY           |

**D. MONITORING AND REPORTING REQUIREMENTS:**

Monitoring results obtained during each calendar year shall be submitted no later than May 31st of that year to:

Aitkin County Environmental Services  
307 2nd Street NW, Room 219  
Aitkin, MN 56431

The monitoring reports shall be signed by the Permittee. Copies are to be retained by the Permittee. Any sampling and laboratory testing procedures shall be performed in accordance with Standard Methods at a Minnesota Department of Health approved laboratory. All sampling and testing costs shall be the responsibility of the Permittee. Monitoring plans may be modified as necessary and reapproved by Aitkin County Environmental Services.

The Permittee shall notify Aitkin County Environmental Services within thirty (30) days when monitoring results do not meet the monitoring plan requirements of this permit.

The owner has secured the services of **Septic Check** as the Service Provider or qualified individual for this system. The Service Provider or qualified individual is hereby authorized to report the required monitoring data and routine maintenance service records to Aitkin County Environmental Services.

**E. MITIGATION PLAN:**

Follow management plan, reduce flow if needed