

FIELD EVALUATION SHEET

NAME Kirk Dotzler APP # 2016-000071
PERMIT # _____
PARCEL # _____ TWP _____ SECTION _____

CHECK THE FOLLOWING PRIOR TO INSPECTION

- _____ NAME OF SITE EVALUATOR
- _____ NAME OF DESIGNER
- _____ NAME OF INSTALLER
- 1/4 _____ LOT OF RECORD BEFORE 1-21-92 (SL) IR 1-10-95 (NSL), IF NO, ALT. SITE? _____
- _____ SITE PLAN WITH SETBACK DISTANCES AND DIMENSIONS
- _____ ARE ISTS SITES PROTECTED FROM DAMAGE? IF NOT, WHEN _____
- _____ DESIGN _____ PERC TESTS _____ SOIL BORINGS, 2 PER SITE
- _____ NUMBER OF BEDROOMS (INCLUDE POTENTIAL)
- _____ CROSS SECTION SHEET _____ TRENCH DESIGN SHEET
- _____ MOUND DESIGN SHEET _____ OTHER OR PERFORM.
- _____ PRESSURE DISTRIBUTION SHEET _____ PUMP CALC. TEST
- _____ WATER USE CALCULATIONS _____
- _____ GARBAGE DISPOSAL _____ HOT TUB
- _____ EASEMENTS ON LOT, IS ROAD PUBLIC OR PRIVATE SEE DEED/PLAT
- _____ NATURAL LANDSCAPE PROTECTION PLAN

STAKING: BUILDINGS _____, DRAINFIELD _____, BORINGS _____, WELL _____
BUILDING SETBACKS: ROAD _____, SIDE _____, REAR _____, BLUFF _____,
LAKE/RIVER _____

COMPLETE DURING SITE EVALUATION

_____ BUILDINGS STAKED _____ DRAINFIELD STAKED _____ BORINGS STAKED
_____ WELL STAKED

SETBACKS (MEASURE DISTANCE)

	<u>DRAINFIELD</u>	<u>HOUSE</u>
FLOOD PLAIN	YES/NO	YES/NO
WETLANDS	YES/NO	YES/NO
LAKE, RIVER, PROTECTED WATERS	_____	_____
ROAD RIGHT OF WAY	<u>>100'</u>	<u>>100'</u>
BLUFF	_____	_____
SIDE LOT LINE	<u>>100'</u>	<u>>100'</u>
REAR LOT LINE	_____	_____
HOUSE OR OTHER STRUCTURE	_____	_____
WELL	<u>>50'</u>	<u>>50'</u>
EASEMENTS	_____	_____
NEIGHBORING WELL (S) TO ISTS	(1) _____ (2) _____	(3) _____ (4) _____
DRAINFIELD AREA DISTURBED	_____	_____

CONFORMING SEPTIC SYSTEM: _____ YES _____ NO If no, list reasons below.

COMMENTS OR PROBLEMS (drainage, swales, wetlands, need gutters, etc.) New septic

APPROVED: YES OR NO

INSPECTORS NAME KT DATE 4-20-16 # PICTURES _____

SOIL BORING LOGS AND SKETCH PLAN ON REVERSE SIDE

SOIL BORING LOG #1			SOIL BORING LOG #2		
DEPTH	TEXTURE	COLOR	DEPTH	TEXTURE	COLOR
0-4"	Top soil				
4-12"	Clay loam	10yr 5/3			
<p>Bored to 18". Soil in the 12-18" range had some indication of redox</p> <p>Spoke to installer on phone about digging a pit to verify soils before mound construction</p>					

IDENTIFY LOCATIONS OF: (BORINGS, NEIGHBORING STRUCTURES, WELLS, DRAINFIELDS, DRAINAGE PATTERNS, OR OTHER FEATURES THAT MAY IMPACT THE SITE).