

FIELD EVALUATION SHEET

NAME Chad Tempesta PERMIT # _____
 PARCEL # 29-0-012701 TWP Shamrock SECTION 6

CHECK THE FOLLOWING PRIOR TO INSPECTION

 _____ NAME OF SITE EVALUATOR
 _____ NAME OF DESIGNER
 _____ NAME OF INSTALLER

 _____ LOT OF RECORD BEFORE 1-21-92 (SL) IR 1-10-95 (NSL), IF NO, ALT. SITE?
 _____ SITE PLAN WITH SETBACK DISTANCES AND DIMENSIONS
 _____ ARE ISTS SITES PROTECTED FROM DAMAGE? IF NOT, WHEN _____
 _____ DESIGN _____ PERC TESTS _____ SOIL BORINGS, 2 PER SITE
 _____ NUMBER OF BEDROOMS (INCLUDE POTENTIAL)
 _____ CROSS SECTION SHEET _____ TRENCH DESIGN SHEET
 _____ MOUND DESIGN SHEET _____ OTHER OR PERFORM.
 _____ PRESSURE DISTRIBUTION SHEET _____ PUMP CALC. TEST
 _____ WATER USE CALCULATIONS _____
 _____ GARBAGE DISPOSAL _____ HOT TUB
 _____ EASEMENTS ON LOT, IS ROAD PUBLIC OR PRIVATE SEE DEED/PLAT
 _____ NATURAL LANDSCAPE PROTECTION PLAN

STAKING: BUILDINGS _____, DRAINFIELD _____, BORINGS _____, WELL _____
 BUILDING SETBACKS: ROAD _____, SIDE _____, REAR _____, BLUFF _____,
 LAKE/RIVER _____

COMPLETE DURING SITE EVALUATION
 _____ BUILDINGS STAKED _____ DRAINFIELD STAKED _____ BORINGS STAKED
 _____ WELL STAKED

SETBACKS (MEASURE DISTANCE)

	<u>DRAINFIELD</u>	<u>HOUSE</u>	
	YES/NO	YES/NO	
FLOOD PLAIN			
WETLANDS			
LAKE, RIVER, PROTECTED WATERS			
ROAD RIGHT OF WAY			
BLUFF			
SIDE LOT LINE			
REAR LOT LINE			
HOUSE OR OTHER STRUCTURE			
WELL			
EASEMENTS			
NEIGHBORING WELL (S) TO ISTS	(1) _____	(2) _____	(3) _____ (4) _____
DRAINFIELD AREA DISTURBED	_____		

*out of F.P. at res.
See attached survey for set backs*

CONFORMING SEPTIC SYSTEM: X YES _____ NO If no, list reasons below.
 COMMENTS OR PROBLEMS (drainage, swales, wetlands, need gutters, etc.) _____

Using shoreline averaging Neighbors are 19' and 27' from Ditch. Must be a minimum of 50'

APPROVED: (YES) OR NO

INSPECTORS NAME (KT) DATE 6-1-16 # PICTURES _____

SOIL BORING LOGS AND SKETCH PLAN ON REVERSE SIDE